

TEST REPORT

EN 50549-2:2019

Requirements for generating plants to be connected in parallel with distribution networks

Part 2: Connection to a MV distribution network - Generating plants up to and including type B

Report

Report Number : 6138142.51V1.1
 Date of issue : 2023-05-04
 Total number of pages : 358

Testing Laboratory : DEKRA Testing and Certification (Suzhou) Co., Ltd.
 Address : No.99, Hongye Road, Suzhou Industrial Park, Suzhou, Jiangsu, P.R. China

Applicant's name : Huawei Technologies Co., Ltd.
 Address : Administration Building, Headquarters of Huawei Technologies Co., Ltd., Bantian, Longgang District, Shenzhen, Guangdong, 518129, China

Test specification:

Standard : EN 50549-2:2019
 Test procedure : Type test
 Non-standard test method : N/A

Test Report Form No. : EN 50549-2_V2.0
 Test Report Form(s) Originator : DEKRA Testing and Certification (Suzhou) Co., Ltd.
 Master TRF : Dated 2021-10-28

Test item description : SOLAR INVERTER
 Trade Mark : 
 Manufacturer : Same as applicant
 Model/Type reference : SUN2000-100KTL-M2, SUN2000-115KTL-M2

Ratings	Operating temperature range: - 25°C to + 60°C Protective class: I Ingress protection rating: IP66 Power factor range (adjustable): 0.8 leading...0.8 lagging SUN2000-100KTL-M2: PV input: max 1100 Vdc, MPPT voltage range: 200-1000 Vdc, Isc PV: 10 × 40 A, max 10 × 30 A AC output: 3/N/PE, 400 Vac, rated 144.4 A, max 160.4 A, 480 Vac, rated 120.3 A, max 133.7 A, 50 Hz, rated power 100 kW, max 110 kVA SUN2000-115KTL-M2: PV input: max 1100 Vdc, MPPT voltage range: 200-1000 Vdc, Isc PV: 10 × 40 A, max 10 × 30 A AC output: 3/N/PE, 400 Vac, rated 166.0 A, max 182.3 A, 480 Vac, rated 138.4 A, max 151.9 A, 50 Hz, rated power 115 kW, max 125 kVA

EN 50549-2

Clause	Requirement - Test								Result - Remark		Verdict										
4.8	TABLE: Power quality - Harmonic emission										P										
☒ Opinion 2: Power generating unit (individual device) and power generating system which is $I_n > 75A$:																					
Model: SUN2000-100KTL-M2(400Vac)																					
Harmonics																					
P/P _n [%]	0-5	10	20	30	40	50	60	70	80	90	100										
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]										
2	0.027	0.031	0.029	0.037	0.050	0.083	0.090	0.094	0.113	0.084	0.089										
3	0.029	0.029	0.027	0.028	0.050	0.151	0.249	0.162	0.046	0.097	0.115										
4	0.036	0.037	0.036	0.040	0.038	0.094	0.088	0.124	0.150	0.110	0.121										
5	0.043	0.026	0.033	0.018	0.032	0.412	0.461	0.305	0.209	0.164	0.066										
6	0.043	0.041	0.043	0.045	0.048	0.057	0.045	0.040	0.037	0.026	0.024										
7	0.036	0.029	0.043	0.058	0.015	0.322	0.547	0.270	0.090	0.082	0.056										
8	0.017	0.019	0.022	0.021	0.021	0.032	0.028	0.046	0.029	0.019	0.023										
9	0.014	0.021	0.017	0.025	0.025	0.044	0.104	0.102	0.054	0.036	0.027										
10	0.009	0.007	0.006	0.007	0.011	0.025	0.027	0.032	0.031	0.030	0.025										
11	0.038	0.013	0.026	0.032	0.054	0.255	0.212	0.118	0.121	0.062	0.115										
12	0.009	0.007	0.009	0.009	0.012	0.022	0.028	0.026	0.020	0.023	0.020										
13	0.022	0.013	0.026	0.038	0.029	0.338	0.314	0.167	0.088	0.114	0.074										
14	0.009	0.011	0.009	0.009	0.012	0.022	0.016	0.017	0.022	0.022	0.032										
15	0.020	0.022	0.017	0.023	0.025	0.093	0.091	0.109	0.095	0.071	0.044										
16	0.010	0.009	0.012	0.011	0.012	0.030	0.023	0.020	0.014	0.013	0.011										
17	0.034	0.027	0.012	0.043	0.068	0.207	0.179	0.199	0.198	0.185	0.222										
18	0.009	0.008	0.007	0.008	0.008	0.020	0.017	0.017	0.013	0.016	0.019										
19	0.028	0.020	0.032	0.067	0.095	0.159	0.151	0.220	0.202	0.171	0.158										
20	0.007	0.008	0.008	0.009	0.009	0.017	0.018	0.021	0.025	0.023	0.016										
21	0.020	0.027	0.024	0.021	0.031	0.064	0.091	0.100	0.096	0.075	0.069										
22	0.019	0.016	0.019	0.018	0.016	0.027	0.023	0.026	0.026	0.040	0.034										
23	0.061	0.052	0.027	0.027	0.050	0.158	0.131	0.114	0.161	0.179	0.178										
24	0.021	0.019	0.018	0.019	0.017	0.019	0.017	0.022	0.022	0.016	0.015										
25	0.030	0.031	0.038	0.060	0.081	0.191	0.129	0.202	0.197	0.188	0.202										
26	0.009	0.009	0.008	0.007	0.009	0.029	0.023	0.022	0.027	0.029	0.023										
27	0.038	0.043	0.029	0.022	0.034	0.066	0.078	0.063	0.083	0.079	0.073										
28	0.008	0.009	0.008	0.009	0.008	0.039	0.035	0.033	0.032	0.033	0.027										
29	0.041	0.042	0.020	0.016	0.042	0.126	0.131	0.108	0.175	0.181	0.183										
30	0.009	0.008	0.008	0.007	0.010	0.024	0.019	0.030	0.034	0.026	0.026										
31	0.047	0.032	0.030	0.055	0.077	0.135	0.150	0.196	0.224	0.205	0.209										

EN 50549-2

Clause	Requirement - Test								Result - Remark			Verdict
32	0.009	0.009	0.008	0.008	0.009	0.021	0.019	0.022	0.023	0.029	0.024	
33	0.053	0.057	0.061	0.054	0.038	0.072	0.047	0.052	0.069	0.075	0.070	
34	0.009	0.009	0.008	0.011	0.009	0.026	0.030	0.030	0.033	0.032	0.028	
35	0.086	0.082	0.040	0.034	0.039	0.127	0.152	0.152	0.165	0.181	0.170	
36	0.009	0.009	0.007	0.008	0.008	0.024	0.020	0.020	0.023	0.023	0.024	
37	0.034	0.048	0.015	0.048	0.064	0.123	0.114	0.176	0.221	0.207	0.202	
38	0.008	0.007	0.007	0.009	0.008	0.023	0.022	0.029	0.023	0.023	0.021	
39	0.049	0.065	0.081	0.086	0.076	0.098	0.053	0.049	0.068	0.067	0.060	
40	0.008	0.008	0.007	0.009	0.009	0.031	0.029	0.031	0.029	0.025	0.024	
41	0.075	0.077	0.073	0.053	0.052	0.107	0.133	0.142	0.129	0.016	0.154	
42	0.007	0.007	0.006	0.007	0.008	0.017	0.014	0.013	0.018	0.186	0.021	
43	0.049	0.037	0.028	0.057	0.064	0.138	0.162	0.194	0.190	0.015	0.176	
44	0.007	0.008	0.010	0.011	0.010	0.010	0.010	0.014	0.014	0.080	0.019	
45	0.060	0.056	0.079	0.098	0.109	0.097	0.083	0.087	0.071	0.014	0.077	
46	0.008	0.007	0.008	0.010	0.011	0.010	0.011	0.014	0.014	0.115	0.018	
47	0.075	0.104	0.093	0.068	0.048	0.087	0.116	0.119	0.111	0.015	0.121	
48	0.007	0.006	0.005	0.007	0.007	0.013	0.010	0.012	0.015	0.138	0.020	
49	0.038	0.054	0.042	0.062	0.062	0.120	0.150	0.159	0.142	0.017	0.150	
50	0.006	0.005	0.005	0.007	0.006	0.009	0.008	0.010	0.012	0.056	0.018	

Interharmonics												
P/P _n [%]	0-5	10	20	30	40	50	60	70	80	90	100	
f [Hz]	I [%]											
75	0.043	0.051	0.040	0.048	0.053	0.151	0.125	0.106	0.078	0.061	0.055	
125	0.046	0.050	0.041	0.048	0.053	0.145	0.122	0.105	0.080	0.062	0.058	
175	0.029	0.029	0.025	0.028	0.030	0.136	0.117	0.107	0.105	0.051	0.034	
225	0.024	0.024	0.019	0.021	0.022	0.117	0.108	0.096	0.081	0.036	0.028	
275	0.026	0.025	0.021	0.023	0.026	0.141	0.229	0.208	0.162	0.071	0.037	
325	0.022	0.023	0.019	0.019	0.021	0.123	0.148	0.113	0.095	0.059	0.031	
375	0.024	0.024	0.020	0.022	0.024	0.123	0.192	0.163	0.125	0.063	0.040	
425	0.021	0.022	0.019	0.020	0.021	0.092	0.119	0.083	0.067	0.056	0.030	
475	0.022	0.022	0.019	0.019	0.021	0.055	0.049	0.044	0.038	0.033	0.034	
525	0.023	0.022	0.019	0.020	0.020	0.050	0.043	0.038	0.035	0.028	0.025	
575	0.024	0.024	0.020	0.022	0.021	0.083	0.071	0.063	0.057	0.036	0.027	
625	0.025	0.025	0.021	0.021	0.021	0.103	0.081	0.062	0.048	0.039	0.027	
675	0.026	0.024	0.021	0.021	0.022	0.081	0.070	0.062	0.057	0.037	0.028	
725	0.026	0.025	0.022	0.022	0.023	0.114	0.081	0.062	0.048	0.040	0.031	

EN 50549-2

Clause	Requirement - Test							Result - Remark			Verdict
775	0.026	0.025	0.022	0.022	0.024	0.054	0.045	0.040	0.038	0.033	0.029
825	0.027	0.026	0.023	0.023	0.024	0.053	0.044	0.039	0.036	0.032	0.030
875	0.030	0.029	0.024	0.026	0.025	0.054	0.047	0.041	0.038	0.033	0.030
925	0.030	0.030	0.025	0.027	0.027	0.055	0.048	0.041	0.038	0.033	0.030
975	0.031	0.032	0.025	0.029	0.026	0.055	0.048	0.042	0.039	0.034	0.031
1025	0.032	0.032	0.026	0.029	0.028	0.057	0.047	0.043	0.040	0.036	0.032
1075	0.033	0.031	0.032	0.032	0.034	0.057	0.046	0.043	0.040	0.035	0.032
1125	0.049	0.042	0.060	0.050	0.062	0.059	0.049	0.044	0.042	0.037	0.034
1175	0.080	0.079	0.078	0.075	0.074	0.060	0.053	0.047	0.043	0.037	0.034
1225	0.076	0.081	0.079	0.077	0.076	0.063	0.056	0.049	0.045	0.038	0.035
1275	0.079	0.086	0.064	0.072	0.055	0.066	0.056	0.050	0.047	0.040	0.036
1325	0.044	0.050	0.033	0.038	0.031	0.098	0.069	0.053	0.049	0.041	0.037
1375	0.034	0.035	0.029	0.031	0.030	0.158	0.116	0.061	0.051	0.042	0.038
1425	0.033	0.036	0.032	0.033	0.034	0.149	0.131	0.102	0.064	0.047	0.043
1475	0.037	0.045	0.032	0.035	0.033	0.137	0.124	0.122	0.104	0.070	0.067
1525	0.035	0.037	0.029	0.033	0.032	0.086	0.095	0.115	0.110	0.097	0.087
1575	0.035	0.034	0.027	0.031	0.032	0.073	0.067	0.094	0.108	0.094	0.084
1625	0.033	0.032	0.025	0.031	0.031	0.077	0.067	0.069	0.086	0.085	0.073
1675	0.030	0.030	0.024	0.029	0.030	0.075	0.066	0.068	0.069	0.063	0.057
1725	0.031	0.030	0.024	0.031	0.031	0.074	0.067	0.071	0.073	0.059	0.056
1775	0.032	0.032	0.024	0.032	0.032	0.073	0.070	0.072	0.073	0.063	0.059
1825	0.029	0.029	0.022	0.029	0.030	0.073	0.069	0.070	0.075	0.070	0.065
1875	0.029	0.028	0.021	0.028	0.030	0.068	0.065	0.074	0.097	0.106	0.096
1925	0.028	0.026	0.021	0.028	0.029	0.067	0.067	0.104	0.118	0.089	0.092
1975	0.025	0.025	0.020	0.025	0.028	0.075	0.088	0.109	0.092	0.090	0.084

Higher Frequencies											
P/P _n [%]	0-5	10	20	30	40	50	60	70	80	90	100
f [kHz]	I [%]										
2.1	0.100	0.097	0.090	0.097	0.098	0.244	0.273	0.279	0.287	0.267	0.266
2.3	0.097	0.120	0.118	0.126	0.133	0.223	0.206	0.170	0.176	0.168	0.166
2.5	0.067	0.086	0.082	0.111	0.137	0.196	0.200	0.202	0.207	0.190	0.190
2.7	0.087	0.097	0.094	0.089	0.074	0.203	0.197	0.202	0.203	0.207	0.217
2.9	0.090	0.094	0.090	0.096	0.121	0.207	0.175	0.157	0.165	0.160	0.147
3.1	0.059	0.052	0.053	0.071	0.103	0.201	0.208	0.186	0.151	0.142	0.138
3.3	0.055	0.063	0.077	0.086	0.103	0.244	0.199	0.199	0.189	0.167	0.148
3.5	0.058	0.078	0.094	0.111	0.134	0.310	0.295	0.246	0.194	0.163	0.156

EN 50549-2											
Clause	Requirement - Test							Result - Remark			Verdict
3.7	0.038	0.043	0.044	0.050	0.067	0.160	0.167	0.148	0.132	0.122	0.118
3.9	0.053	0.054	0.053	0.065	0.068	0.177	0.144	0.168	0.187	0.179	0.167
4.1	0.036	0.040	0.051	0.064	0.073	0.184	0.175	0.170	0.157	0.148	0.137
4.3	0.030	0.043	0.035	0.045	0.044	0.103	0.121	0.109	0.110	0.102	0.103
4.5	0.044	0.057	0.048	0.056	0.057	0.162	0.144	0.149	0.145	0.141	0.136
4.7	0.032	0.029	0.044	0.054	0.062	0.163	0.172	0.152	0.119	0.113	0.110
4.9	0.028	0.046	0.041	0.046	0.049	0.105	0.129	0.106	0.099	0.086	0.089
5.1	0.032	0.055	0.057	0.061	0.058	0.119	0.138	0.148	0.132	0.121	0.119
5.3	0.023	0.034	0.041	0.059	0.060	0.113	0.149	0.132	0.095	0.088	0.088
5.5	0.028	0.037	0.044	0.049	0.056	0.107	0.100	0.099	0.114	0.097	0.095
5.7	0.025	0.041	0.044	0.052	0.055	0.088	0.089	0.107	0.122	0.112	0.103
5.9	0.019	0.028	0.025	0.031	0.034	0.079	0.067	0.066	0.065	0.054	0.058
6.1	0.025	0.033	0.026	0.029	0.031	0.082	0.071	0.071	0.085	0.091	0.094
6.3	0.019	0.025	0.025	0.030	0.036	0.065	0.056	0.058	0.067	0.069	0.072
6.5	0.018	0.022	0.023	0.023	0.030	0.065	0.050	0.047	0.048	0.045	0.045
6.7	0.019	0.026	0.026	0.023	0.024	0.066	0.060	0.048	0.045	0.046	0.049
6.9	0.015	0.021	0.023	0.024	0.028	0.033	0.040	0.042	0.042	0.046	0.049
7.1	0.017	0.022	0.029	0.025	0.029	0.048	0.051	0.039	0.035	0.031	0.033
7.3	0.015	0.021	0.031	0.029	0.027	0.044	0.039	0.043	0.035	0.030	0.033
7.5	0.012	0.015	0.022	0.022	0.024	0.041	0.032	0.029	0.028	0.029	0.029
7.7	0.013	0.018	0.029	0.029	0.032	0.046	0.033	0.040	0.036	0.030	0.028
7.9	0.012	0.017	0.030	0.032	0.032	0.061	0.042	0.039	0.035	0.028	0.026
8.1	0.010	0.013	0.019	0.020	0.022	0.053	0.047	0.031	0.022	0.021	0.020
8.3	0.011	0.014	0.027	0.032	0.035	0.055	0.031	0.038	0.038	0.030	0.025
8.5	0.010	0.013	0.027	0.032	0.036	0.059	0.048	0.043	0.040	0.031	0.025
8.7	0.008	0.011	0.018	0.020	0.019	0.041	0.044	0.031	0.020	0.019	0.017
8.9	0.009	0.012	0.024	0.030	0.038	0.052	0.039	0.039	0.042	0.034	0.059

Note(s):

Each phase output current > 75A, it shall be complied with EN 61000-4-7+A1.

The worst case of three phases has been choose.

EN 50549-2

Clause	Requirement - Test								Result - Remark		Verdict												
4.8	TABLE: Power quality - Harmonic emission										P												
<input checked="" type="checkbox"/> Opinion 2: Power generating unit (individual device) and power generating system which is $I_n > 75A$:																							
Model: SUN2000-115KTL-M2 (400Vac)																							
Harmonics																							
P/P _n [%]	0-5	10	20	30	40	50	60	70	80	90	100												
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]												
2	0.560	0.186	0.109	0.121	0.145	0.139	0.120	0.114	0.115	0.126	0.124												
3	0.688	0.144	0.054	0.079	0.137	0.099	0.153	0.119	0.150	0.107	0.101												
4	1.328	0.290	0.138	0.101	0.084	0.077	0.063	0.070	0.051	0.032	0.029												
5	0.834	0.185	0.203	0.139	0.181	0.112	0.331	0.184	0.118	0.275	0.444												
6	1.194	0.290	0.134	0.086	0.078	0.069	0.053	0.068	0.060	0.046	0.048												
7	0.856	0.206	0.200	0.125	0.169	0.155	0.234	0.100	0.133	0.242	0.453												
8	0.796	0.185	0.086	0.056	0.046	0.036	0.028	0.019	0.025	0.026	0.021												
9	0.467	0.083	0.041	0.028	0.064	0.111	0.053	0.060	0.033	0.035	0.066												
10	0.258	0.067	0.035	0.022	0.018	0.022	0.016	0.015	0.014	0.015	0.023												
11	0.429	0.110	0.063	0.081	0.099	0.129	0.134	0.086	0.077	0.205	0.104												
12	0.249	0.071	0.028	0.020	0.015	0.016	0.017	0.017	0.017	0.019	0.013												
13	0.329	0.082	0.048	0.053	0.047	0.126	0.124	0.077	0.066	0.128	0.144												
14	0.398	0.083	0.041	0.027	0.025	0.026	0.020	0.022	0.014	0.016	0.020												
15	0.628	0.083	0.053	0.025	0.035	0.064	0.062	0.034	0.042	0.037	0.037												
16	0.288	0.064	0.033	0.019	0.015	0.016	0.013	0.011	0.010	0.012	0.015												
17	0.655	0.134	0.111	0.138	0.148	0.181	0.210	0.144	0.116	0.119	0.147												
18	0.275	0.063	0.026	0.018	0.016	0.015	0.012	0.012	0.012	0.013	0.010												
19	0.352	0.082	0.083	0.107	0.108	0.126	0.164	0.144	0.152	0.163	0.179												
20	0.238	0.050	0.025	0.020	0.017	0.016	0.014	0.012	0.013	0.012	0.012												
21	0.653	0.097	0.061	0.050	0.086	0.068	0.075	0.048	0.068	0.070	0.065												
22	0.298	0.064	0.030	0.040	0.026	0.024	0.015	0.014	0.011	0.013	0.013												
23	0.723	0.094	0.079	0.099	0.151	0.170	0.173	0.159	0.129	0.108	0.158												
24	0.307	0.070	0.040	0.047	0.034	0.030	0.023	0.022	0.016	0.017	0.010												
25	0.588	0.111	0.095	0.111	0.106	0.141	0.178	0.172	0.210	0.191	0.157												
26	0.649	0.130	0.060	0.021	0.016	0.015	0.015	0.019	0.019	0.017	0.011												
27	0.749	0.157	0.087	0.051	0.101	0.067	0.077	0.073	0.073	0.076	0.098												
28	0.667	0.155	0.042	0.022	0.016	0.015	0.012	0.013	0.015	0.021	0.018												
29	0.959	0.174	0.074	0.092	0.135	0.203	0.172	0.167	0.148	0.151	0.186												
30	0.282	0.076	0.032	0.022	0.017	0.016	0.014	0.014	0.017	0.020	0.020												
31	0.663	0.158	0.085	0.092	0.123	0.233	0.218	0.237	0.234	0.200	0.160												

EN 50549-2

Clause	Requirement - Test								Result - Remark			Verdict
	32	0.264	0.061	0.031	0.021	0.016	0.015	0.019	0.015	0.014	0.012	
33	1.268	0.210	0.094	0.042	0.051	0.058	0.075	0.093	0.075	0.071	0.097	
34	0.266	0.059	0.030	0.020	0.018	0.014	0.013	0.012	0.013	0.013	0.017	0.012
35	1.219	0.149	0.055	0.082	0.135	0.176	0.178	0.182	0.159	0.173	0.204	
36	0.268	0.062	0.028	0.020	0.018	0.016	0.014	0.016	0.016	0.021	0.017	
37	0.648	0.249	0.092	0.084	0.140	0.219	0.208	0.223	0.233	0.194	0.136	
38	0.253	0.063	0.027	0.018	0.016	0.016	0.015	0.017	0.016	0.018	0.021	
39	1.311	0.314	0.183	0.088	0.037	0.026	0.065	0.074	0.066	0.058	0.068	
40	0.364	0.086	0.035	0.020	0.015	0.016	0.014	0.015	0.020	0.027	0.022	
41	0.035	0.031	0.027	0.038	0.064	0.093	0.099	0.131	0.125	0.136	0.171	
42	0.007	0.008	0.008	0.006	0.007	0.010	0.011	0.018	0.020	0.023	0.019	
43	0.013	0.025	0.030	0.039	0.067	0.119	0.103	0.138	0.159	0.156	0.172	
44	0.004	0.005	0.005	0.006	0.007	0.010	0.012	0.016	0.014	0.013	0.016	
45	0.066	0.091	0.091	0.089	0.091	0.092	0.085	0.108	0.085	0.078	0.126	
46	0.004	0.004	0.004	0.006	0.007	0.010	0.009	0.011	0.012	0.016	0.014	
47	0.026	0.030	0.033	0.038	0.070	0.080	0.086	0.115	0.119	0.113	0.142	
48	0.003	0.004	0.004	0.004	0.006	0.006	0.007	0.010	0.010	0.011	0.013	
49	0.011	0.021	0.024	0.029	0.053	0.086	0.094	0.118	0.129	0.126	0.127	
50	0.003	0.003	0.003	0.004	0.005	0.006	0.006	0.009	0.009	0.010	0.011	

Interharmonics												
P/P _n [%]	0-5	10	20	30	40	50	60	70	80	90	100	
f [Hz]	I [%]											
75	1.566	0.355	0.154	0.147	0.110	0.113	0.093	0.096	0.113	0.090	0.078	
125	1.691	0.372	0.158	0.144	0.110	0.082	0.087	0.091	0.093	0.082	0.071	
175	0.864	0.200	0.098	0.153	0.122	0.127	0.107	0.110	0.115	0.109	0.092	
225	0.754	0.153	0.074	0.116	0.092	0.089	0.091	0.124	0.129	0.089	0.067	
275	0.807	0.169	0.094	0.134	0.147	0.104	0.201	0.173	0.142	0.156	0.193	
325	0.683	0.146	0.077	0.121	0.105	0.063	0.100	0.128	0.128	0.125	0.133	
375	0.734	0.152	0.085	0.099	0.122	0.041	0.155	0.141	0.109	0.142	0.185	
425	0.695	0.155	0.078	0.101	0.081	0.037	0.075	0.053	0.047	0.106	0.125	
475	0.679	0.158	0.073	0.062	0.048	0.060	0.039	0.035	0.032	0.036	0.041	
525	0.734	0.163	0.073	0.058	0.044	0.050	0.033	0.033	0.029	0.030	0.030	
575	0.774	0.164	0.079	0.079	0.068	0.059	0.067	0.061	0.056	0.063	0.064	
625	0.736	0.173	0.085	0.094	0.064	0.050	0.055	0.043	0.040	0.063	0.072	
675	0.743	0.170	0.081	0.079	0.067	0.041	0.063	0.058	0.054	0.064	0.062	
725	0.814	0.187	0.090	0.099	0.067	0.040	0.054	0.041	0.038	0.064	0.076	

EN 50549-2

Clause	Requirement - Test							Result - Remark			Verdict
775	0.812	0.192	0.089	0.061	0.051	0.043	0.034	0.031	0.029	0.030	0.030
825	0.847	0.200	0.091	0.060	0.051	0.044	0.033	0.030	0.028	0.028	0.027
875	0.884	0.206	0.094	0.063	0.054	0.046	0.036	0.031	0.029	0.030	0.030
925	0.881	0.207	0.097	0.066	0.055	0.046	0.036	0.032	0.030	0.030	0.027
975	0.884	0.207	0.100	0.064	0.056	0.051	0.038	0.034	0.030	0.030	0.028
1025	0.905	0.212	0.103	0.067	0.058	0.077	0.038	0.035	0.031	0.030	0.027
1075	0.938	0.217	0.107	0.076	0.061	0.128	0.038	0.035	0.031	0.029	0.026
1125	1.005	0.235	0.110	0.131	0.092	0.131	0.047	0.036	0.032	0.030	0.027
1175	1.036	0.243	0.113	0.217	0.157	0.122	0.080	0.048	0.035	0.033	0.030
1225	1.026	0.238	0.133	0.213	0.162	0.067	0.106	0.084	0.045	0.035	0.030
1275	1.171	0.255	0.231	0.194	0.152	0.055	0.109	0.095	0.070	0.045	0.030
1325	1.980	0.390	0.340	0.103	0.088	0.058	0.085	0.091	0.082	0.067	0.031
1375	2.516	0.602	0.312	0.085	0.058	0.060	0.049	0.057	0.077	0.075	0.037
1425	2.228	0.633	0.279	0.089	0.060	0.059	0.047	0.041	0.052	0.069	0.054
1475	1.840	0.570	0.144	0.093	0.062	0.059	0.049	0.043	0.041	0.049	0.070
1525	0.998	0.371	0.124	0.088	0.064	0.062	0.050	0.044	0.041	0.041	0.067
1575	0.890	0.245	0.124	0.082	0.066	0.058	0.051	0.045	0.043	0.041	0.055
1625	0.857	0.228	0.120	0.077	0.067	0.062	0.051	0.046	0.044	0.042	0.039
1675	0.783	0.202	0.110	0.073	0.066	0.061	0.051	0.047	0.043	0.041	0.038
1725	0.751	0.189	0.107	0.075	0.069	0.060	0.053	0.047	0.045	0.043	0.041
1775	0.746	0.185	0.098	0.071	0.066	0.058	0.054	0.049	0.048	0.048	0.043
1825	0.733	0.187	0.093	0.068	0.065	0.061	0.055	0.051	0.051	0.049	0.044
1875	0.704	0.175	0.092	0.066	0.061	0.055	0.058	0.055	0.052	0.051	0.046
1925	0.683	0.173	0.088	0.063	0.058	0.057	0.057	0.055	0.056	0.049	0.072
1975	0.675	0.190	0.081	0.061	0.054	0.052	0.058	0.059	0.051	0.052	0.073

Higher Frequencies											
P/P _n [%]	0-5	10	20	30	40	50	60	70	80	90	100
f [kHz]	I [%]										
2.1	2.227	0.504	0.251	0.174	0.230	0.302	0.272	0.302	0.294	0.282	0.242
2.3	2.156	0.497	0.265	0.205	0.222	0.209	0.189	0.195	0.161	0.155	0.179
2.5	1.772	0.447	0.245	0.171	0.165	0.198	0.161	0.171	0.178	0.161	0.130
2.7	1.862	0.345	0.189	0.150	0.164	0.197	0.174	0.165	0.160	0.146	0.155
2.9	1.989	0.419	0.322	0.235	0.204	0.171	0.101	0.085	0.072	0.077	0.130
3.1	1.646	0.304	0.226	0.183	0.170	0.150	0.161	0.163	0.171	0.149	0.103
3.3	1.133	0.297	0.242	0.220	0.193	0.198	0.136	0.140	0.126	0.117	0.136
3.5	1.329	0.373	0.157	0.159	0.138	0.156	0.173	0.182	0.192	0.172	0.157

EN 50549-2											
Clause	Requirement - Test							Result - Remark			Verdict
3.7	1.348	0.287	0.181	0.122	0.103	0.077	0.101	0.083	0.084	0.091	0.086
3.9	1.211	0.183	0.085	0.095	0.117	0.124	0.151	0.131	0.124	0.114	0.121
4.1	1.375	0.261	0.147	0.110	0.117	0.112	0.136	0.126	0.130	0.128	0.117
4.3	0.925	0.221	0.127	0.106	0.091	0.091	0.075	0.071	0.079	0.081	0.083
4.5	1.241	0.196	0.095	0.084	0.087	0.097	0.124	0.120	0.136	0.134	0.120
4.7	1.144	0.193	0.127	0.124	0.117	0.098	0.105	0.112	0.117	0.132	0.125
4.9	0.747	0.176	0.091	0.102	0.103	0.106	0.088	0.084	0.094	0.095	0.095
5.1	0.978	0.196	0.088	0.072	0.091	0.086	0.128	0.131	0.133	0.131	0.115
5.3	0.775	0.182	0.096	0.093	0.091	0.106	0.091	0.101	0.091	0.110	0.123
5.5	0.645	0.170	0.098	0.073	0.084	0.100	0.096	0.099	0.101	0.096	0.104
5.7	0.759	0.169	0.088	0.058	0.057	0.053	0.080	0.083	0.095	0.096	0.090
5.9	0.734	0.175	0.077	0.069	0.072	0.069	0.065	0.064	0.069	0.078	0.108
6.1	0.859	0.187	0.065	0.054	0.046	0.037	0.045	0.052	0.064	0.066	0.075
6.3	0.584	0.148	0.075	0.049	0.053	0.051	0.040	0.041	0.041	0.044	0.051
6.5	0.804	0.196	0.079	0.055	0.051	0.055	0.042	0.044	0.047	0.047	0.043
6.7	0.923	0.238	0.102	0.059	0.049	0.037	0.027	0.031	0.032	0.032	0.026
6.9	0.512	0.178	0.080	0.043	0.039	0.041	0.032	0.030	0.029	0.031	0.025
7.1	0.892	0.243	0.120	0.073	0.050	0.040	0.025	0.029	0.028	0.030	0.027
7.3	0.913	0.252	0.145	0.087	0.058	0.036	0.025	0.025	0.022	0.021	0.018
7.5	0.519	0.167	0.068	0.042	0.030	0.026	0.022	0.021	0.022	0.022	0.019
7.7	0.864	0.239	0.149	0.096	0.064	0.040	0.023	0.023	0.018	0.018	0.017
7.9	0.850	0.227	0.144	0.103	0.071	0.044	0.023	0.020	0.016	0.014	0.015
8.1	0.501	0.158	0.074	0.040	0.033	0.026	0.021	0.019	0.016	0.014	0.015
8.3	0.788	0.217	0.136	0.102	0.076	0.053	0.028	0.023	0.015	0.013	0.014
8.5	0.735	0.214	0.128	0.098	0.079	0.058	0.028	0.023	0.016	0.012	0.014
8.7	0.450	0.163	0.081	0.041	0.030	0.025	0.024	0.019	0.016	0.013	0.012
8.9	0.643	0.200	0.126	0.096	0.081	0.063	0.038	0.030	0.020	0.014	0.012

Note(s):

Each phase output current > 75A, it shall be complied with EN 61000-4-7+A1.

The worst case of three phases has been choose.

EN 50549-2

Clause	Requirement - Test								Result - Remark		Verdict										
4.8	TABLE: Power quality - Harmonic emission										P										
☒ Opinion 2: Power generating unit (individual device) and power generating system which is $I_n > 75A$:																					
Model: SUN2000-100KTL-M2 (480Vac)																					
Harmonics																					
P/P _n [%]	0-5	10	20	30	40	50	60	70	80	90	100										
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]										
2	4.087	0.879	0.357	0.265	0.212	0.205	0.162	0.145	0.161	0.144	0.136										
3	0.971	0.191	0.052	0.033	0.076	0.172	0.181	0.188	0.213	0.088	0.106										
4	4.540	0.563	0.418	0.288	0.221	0.185	0.155	0.121	0.110	0.098	0.078										
5	3.253	0.455	0.209	0.098	0.142	0.176	0.214	0.185	0.116	0.230	0.036										
6	1.324	0.512	0.339	0.233	0.172	0.123	0.101	0.062	0.048	0.044	0.048										
7	3.054	1.124	0.545	0.397	0.269	0.380	0.207	0.085	0.326	0.253	0.106										
8	1.179	0.240	0.114	0.071	0.043	0.019	0.024	0.018	0.016	0.021	0.028										
9	1.271	0.119	0.107	0.071	0.028	0.067	0.048	0.045	0.085	0.129	0.068										
10	1.069	0.409	0.218	0.138	0.096	0.068	0.063	0.043	0.041	0.037	0.038										
11	1.957	0.289	0.184	0.093	0.075	0.084	0.141	0.063	0.181	0.103	0.083										
12	1.429	0.364	0.171	0.101	0.072	0.051	0.044	0.042	0.035	0.035	0.028										
13	1.356	0.142	0.158	0.125	0.123	0.163	0.051	0.056	0.167	0.069	0.062										
14	0.784	0.080	0.051	0.037	0.033	0.021	0.023	0.014	0.018	0.013	0.012										
15	1.054	0.212	0.060	0.029	0.026	0.033	0.060	0.057	0.069	0.098	0.053										
16	0.990	0.187	0.085	0.039	0.031	0.018	0.016	0.011	0.011	0.016	0.019										
17	1.605	0.339	0.134	0.140	0.136	0.162	0.159	0.147	0.194	0.193	0.143										
18	0.662	0.202	0.104	0.059	0.051	0.039	0.026	0.013	0.013	0.014	0.015										
19	2.470	0.258	0.244	0.214	0.212	0.276	0.268	0.230	0.286	0.299	0.274										
20	0.465	0.095	0.065	0.045	0.041	0.044	0.038	0.027	0.025	0.024	0.018										
21	1.045	0.171	0.051	0.031	0.032	0.047	0.048	0.068	0.028	0.043	0.020										
22	0.633	0.202	0.112	0.075	0.050	0.041	0.032	0.029	0.025	0.023	0.025										
23	1.341	0.197	0.082	0.050	0.082	0.095	0.103	0.102	0.085	0.113	0.115										
24	0.528	0.205	0.096	0.060	0.056	0.036	0.031	0.025	0.028	0.023	0.021										
25	1.284	0.198	0.085	0.152	0.145	0.222	0.205	0.212	0.220	0.210	0.231										
26	0.428	0.074	0.040	0.028	0.024	0.015	0.014	0.012	0.012	0.013	0.015										
27	0.731	0.136	0.108	0.074	0.072	0.077	0.056	0.046	0.017	0.024	0.027										
28	0.570	0.121	0.051	0.030	0.028	0.016	0.017	0.014	0.014	0.010	0.013										
29	2.078	0.175	0.084	0.139	0.146	0.156	0.180	0.205	0.229	0.210	0.201										
30	0.408	0.122	0.053	0.030	0.020	0.019	0.018	0.018	0.018	0.013	0.012										
31	0.892	0.182	0.043	0.069	0.095	0.161	0.163	0.185	0.200	0.239	0.237										

EN 50549-2

Clause	Requirement - Test								Result - Remark			Verdict
32	0.478	0.081	0.038	0.027	0.019	0.017	0.014	0.012	0.014	0.019	0.016	
33	0.833	0.134	0.047	0.031	0.023	0.022	0.021	0.039	0.039	0.061	0.063	
34	0.484	0.072	0.041	0.025	0.020	0.019	0.017	0.017	0.012	0.012	0.011	
35	1.455	0.190	0.082	0.098	0.131	0.148	0.212	0.241	0.215	0.218	0.227	
36	0.487	0.080	0.032	0.024	0.021	0.017	0.017	0.018	0.019	0.014	0.014	
37	0.977	0.280	0.041	0.041	0.081	0.145	0.146	0.193	0.198	0.223	0.239	
38	0.527	0.080	0.036	0.023	0.018	0.015	0.016	0.015	0.019	0.014	0.013	
39	1.336	0.155	0.099	0.064	0.072	0.046	0.039	0.023	0.046	0.028	0.028	
40	0.392	0.070	0.035	0.023	0.018	0.014	0.019	0.015	0.014	0.012	0.013	
41	0.026	0.030	0.015	0.017	0.030	0.041	0.073	0.102	0.089	0.121	0.144	
42	0.009	0.008	0.005	0.006	0.007	0.006	0.008	0.007	0.010	0.012	0.013	
43	0.012	0.031	0.021	0.027	0.043	0.069	0.094	0.111	0.127	0.153	0.175	
44	0.013	0.010	0.007	0.007	0.008	0.008	0.009	0.011	0.011	0.015	0.016	
45	0.026	0.027	0.017	0.021	0.025	0.037	0.040	0.047	0.031	0.027	0.039	
46	0.008	0.007	0.009	0.010	0.010	0.012	0.012	0.013	0.016	0.011	0.014	
47	0.044	0.023	0.022	0.017	0.022	0.032	0.056	0.064	0.060	0.082	0.112	
48	0.008	0.005	0.004	0.006	0.006	0.007	0.007	0.008	0.010	0.011	0.014	
49	0.040	0.041	0.027	0.031	0.049	0.069	0.080	0.098	0.101	0.127	0.139	
50	0.013	0.007	0.007	0.008	0.006	0.006	0.007	0.007	0.007	0.008	0.010	

Interharmonics												
P/P _n [%]	0-5	10	20	30	40	50	60	70	80	90	100	
f [Hz]	I [%]											
75	1.445	0.369	0.213	0.102	0.076	0.069	0.057	0.051	0.055	0.052	0.063	
125	1.561	0.354	0.207	0.099	0.079	0.070	0.056	0.053	0.056	0.054	0.062	
175	1.280	0.341	0.147	0.096	0.073	0.066	0.056	0.050	0.055	0.087	0.104	
225	1.132	0.274	0.118	0.073	0.059	0.059	0.043	0.041	0.054	0.042	0.095	
275	1.174	0.281	0.130	0.091	0.078	0.088	0.068	0.068	0.102	0.095	0.133	
325	1.105	0.256	0.117	0.078	0.062	0.061	0.055	0.048	0.064	0.057	0.097	
375	1.136	0.268	0.129	0.089	0.074	0.079	0.060	0.060	0.096	0.076	0.108	
425	1.106	0.253	0.124	0.083	0.060	0.057	0.052	0.044	0.047	0.055	0.047	
475	1.085	0.259	0.125	0.080	0.058	0.049	0.039	0.035	0.036	0.032	0.034	
525	1.093	0.249	0.119	0.074	0.054	0.047	0.036	0.031	0.032	0.029	0.030	
575	1.121	0.243	0.120	0.078	0.058	0.052	0.041	0.037	0.048	0.042	0.050	
625	1.318	0.265	0.127	0.084	0.060	0.051	0.045	0.038	0.040	0.039	0.039	
675	1.276	0.267	0.122	0.082	0.060	0.053	0.042	0.039	0.049	0.042	0.049	
725	1.402	0.299	0.134	0.093	0.066	0.053	0.047	0.041	0.042	0.043	0.039	

EN 50549-2

Clause	Requirement - Test								Result - Remark			Verdict
775	2.026	0.376	0.146	0.093	0.066	0.050	0.041	0.038	0.035	0.032	0.030	
825	3.371	0.659	0.189	0.105	0.078	0.051	0.043	0.036	0.035	0.032	0.031	
875	3.705	0.855	0.357	0.182	0.124	0.058	0.045	0.037	0.037	0.034	0.031	
925	3.423	0.874	0.439	0.279	0.190	0.085	0.059	0.040	0.040	0.035	0.032	
975	1.924	0.591	0.452	0.298	0.216	0.156	0.109	0.054	0.058	0.049	0.035	
1025	1.527	0.473	0.322	0.270	0.202	0.189	0.151	0.112	0.103	0.090	0.066	
1075	1.463	0.342	0.166	0.121	0.108	0.176	0.145	0.124	0.109	0.096	0.079	
1125	1.495	0.457	0.246	0.159	0.117	0.107	0.108	0.131	0.108	0.101	0.096	
1175	1.426	0.342	0.162	0.104	0.080	0.063	0.055	0.069	0.061	0.055	0.069	
1225	1.451	0.329	0.150	0.100	0.075	0.065	0.054	0.048	0.047	0.041	0.041	
1275	1.456	0.338	0.150	0.098	0.078	0.065	0.053	0.046	0.046	0.041	0.037	
1325	1.485	0.342	0.154	0.104	0.079	0.064	0.054	0.046	0.046	0.040	0.037	
1375	1.494	0.364	0.173	0.129	0.098	0.079	0.071	0.060	0.057	0.050	0.045	
1425	1.445	0.331	0.136	0.100	0.078	0.064	0.056	0.050	0.047	0.041	0.038	
1475	1.409	0.340	0.163	0.123	0.094	0.078	0.069	0.062	0.059	0.053	0.049	
1525	1.340	0.310	0.134	0.098	0.075	0.066	0.055	0.050	0.050	0.044	0.041	
1575	1.270	0.308	0.135	0.096	0.073	0.066	0.054	0.049	0.051	0.047	0.042	
1625	1.239	0.293	0.132	0.093	0.072	0.065	0.053	0.048	0.050	0.046	0.041	
1675	1.179	0.281	0.122	0.089	0.069	0.067	0.053	0.049	0.050	0.046	0.043	
1725	1.107	0.263	0.116	0.082	0.066	0.064	0.051	0.050	0.051	0.047	0.045	
1775	1.031	0.251	0.108	0.079	0.063	0.058	0.050	0.052	0.052	0.049	0.046	
1825	0.975	0.242	0.104	0.075	0.059	0.057	0.048	0.048	0.050	0.047	0.047	
1875	0.924	0.238	0.093	0.069	0.054	0.053	0.046	0.045	0.049	0.048	0.047	
1925	0.850	0.214	0.089	0.066	0.051	0.051	0.045	0.042	0.048	0.048	0.046	
1975	0.819	0.203	0.081	0.062	0.049	0.048	0.043	0.041	0.046	0.045	0.046	

Higher Frequencies											
P/P _n [%]	0-5	10	20	30	40	50	60	70	80	90	100
f [kHz]	I [%]										
2.1	2.339	0.436	0.177	0.144	0.166	0.204	0.239	0.263	0.249	0.266	0.282
2.3	3.380	0.363	0.199	0.127	0.101	0.098	0.125	0.146	0.131	0.148	0.178
2.5	3.359	0.411	0.230	0.173	0.175	0.194	0.180	0.185	0.171	0.180	0.173
2.7	6.147	0.507	0.251	0.209	0.187	0.163	0.166	0.180	0.164	0.198	0.195
2.9	3.755	0.370	0.245	0.188	0.179	0.140	0.157	0.152	0.138	0.174	0.161
3.1	3.316	0.371	0.145	0.148	0.178	0.193	0.185	0.166	0.156	0.156	0.140
3.3	5.717	0.658	0.261	0.258	0.229	0.204	0.157	0.111	0.091	0.134	0.164
3.5	1.544	0.477	0.189	0.177	0.164	0.144	0.149	0.169	0.172	0.199	0.204

EN 50549-2											
Clause	Requirement - Test							Result - Remark			Verdict
3.7	4.071	0.565	0.121	0.069	0.066	0.069	0.105	0.133	0.128	0.129	0.120
3.9	3.625	0.618	0.185	0.109	0.081	0.088	0.109	0.146	0.156	0.170	0.186
4.1	2.366	0.392	0.122	0.080	0.059	0.063	0.051	0.059	0.078	0.086	0.105
4.3	2.462	0.349	0.143	0.104	0.059	0.057	0.057	0.074	0.077	0.100	0.109
4.5	2.635	0.424	0.125	0.116	0.075	0.068	0.062	0.077	0.094	0.103	0.112
4.7	2.100	0.206	0.109	0.067	0.059	0.056	0.064	0.074	0.085	0.094	0.093
4.9	1.495	0.339	0.124	0.080	0.075	0.083	0.058	0.061	0.076	0.082	0.084
5.1	2.214	0.255	0.089	0.058	0.065	0.063	0.074	0.091	0.114	0.134	0.145
5.3	2.009	0.234	0.126	0.097	0.072	0.057	0.086	0.096	0.105	0.131	0.128
5.5	1.572	0.204	0.097	0.055	0.061	0.065	0.074	0.069	0.089	0.080	0.088
5.7	2.080	0.232	0.093	0.056	0.044	0.054	0.055	0.084	0.098	0.129	0.155
5.9	1.156	0.182	0.078	0.059	0.049	0.041	0.052	0.062	0.060	0.080	0.087
6.1	1.573	0.132	0.059	0.047	0.038	0.031	0.027	0.032	0.036	0.049	0.055
6.3	1.294	0.134	0.065	0.045	0.032	0.023	0.028	0.043	0.047	0.066	0.067
6.5	0.494	0.124	0.045	0.039	0.035	0.024	0.026	0.030	0.030	0.038	0.044
6.7	0.803	0.103	0.046	0.030	0.024	0.025	0.018	0.022	0.025	0.037	0.040
6.9	0.560	0.126	0.048	0.037	0.034	0.027	0.022	0.022	0.025	0.033	0.040
7.1	0.407	0.090	0.041	0.028	0.024	0.023	0.018	0.016	0.017	0.019	0.023
7.3	0.493	0.072	0.054	0.038	0.033	0.028	0.020	0.014	0.014	0.015	0.021
7.5	0.441	0.086	0.055	0.040	0.034	0.029	0.019	0.016	0.010	0.019	0.026
7.7	0.324	0.063	0.044	0.030	0.025	0.020	0.017	0.013	0.010	0.010	0.013
7.9	0.254	0.062	0.040	0.026	0.026	0.019	0.020	0.017	0.012	0.009	0.011
8.1	0.353	0.067	0.026	0.017	0.017	0.016	0.024	0.022	0.017	0.014	0.009
8.3	0.288	0.072	0.035	0.023	0.020	0.014	0.020	0.017	0.011	0.010	0.008
8.5	0.250	0.050	0.035	0.021	0.020	0.016	0.021	0.021	0.013	0.013	0.009
8.7	0.313	0.051	0.042	0.024	0.018	0.016	0.024	0.024	0.017	0.014	0.010
8.9	0.252	0.051	0.030	0.020	0.020	0.015	0.022	0.021	0.016	0.014	0.010

Note(s):

Each phase output current > 75A, it shall be complied with EN 61000-4-7+A1.

The worst case of three phases has been choose.

EN 50549-2

Clause	Requirement - Test								Result - Remark		Verdict												
4.8	TABLE: Power quality - Harmonic emission										P												
☒ Opinion 2: Power generating unit (individual device) and power generating system which is $I_n > 75A$:																							
Model: SUN2000-115KTL-M2 (480Vac)																							
Harmonics																							
P/P _n [%]	0-5	10	20	30	40	50	60	70	80	90	100												
Order	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]	I [%]												
2	2.875	0.524	0.297	0.185	0.129	0.083	0.043	0.025	0.024	0.043	0.055												
3	0.990	0.212	0.066	0.082	0.135	0.120	0.067	0.138	0.081	0.102	0.088												
4	3.561	0.881	0.511	0.345	0.271	0.206	0.139	0.117	0.096	0.082	0.073												
5	2.287	0.384	0.254	0.195	0.507	0.261	0.072	0.156	0.314	0.143	0.081												
6	2.099	0.748	0.373	0.235	0.142	0.116	0.089	0.071	0.047	0.040	0.031												
7	2.003	0.968	0.531	0.349	0.171	0.159	0.234	0.347	0.136	0.160	0.270												
8	0.658	0.196	0.123	0.075	0.060	0.040	0.021	0.017	0.033	0.032	0.026												
9	0.514	0.098	0.038	0.060	0.072	0.058	0.055	0.106	0.043	0.025	0.025												
10	1.024	0.439	0.189	0.129	0.083	0.075	0.053	0.030	0.038	0.033	0.028												
11	1.532	0.285	0.170	0.171	0.160	0.153	0.163	0.187	0.095	0.090	0.085												
12	1.098	0.437	0.188	0.134	0.091	0.083	0.066	0.060	0.049	0.040	0.036												
13	0.804	0.113	0.170	0.118	0.132	0.095	0.057	0.080	0.031	0.038	0.067												
14	0.450	0.101	0.045	0.031	0.030	0.026	0.018	0.015	0.016	0.017	0.020												
15	0.383	0.088	0.044	0.052	0.078	0.030	0.032	0.047	0.036	0.040	0.041												
16	0.321	0.063	0.033	0.022	0.020	0.017	0.016	0.013	0.012	0.012	0.009												
17	1.789	0.235	0.200	0.215	0.249	0.211	0.205	0.190	0.161	0.141	0.111												
18	0.424	0.073	0.045	0.026	0.024	0.020	0.015	0.015	0.014	0.016	0.015												
19	1.216	0.112	0.218	0.182	0.218	0.273	0.271	0.295	0.271	0.262	0.260												
20	0.661	0.179	0.085	0.046	0.038	0.032	0.023	0.017	0.023	0.020	0.018												
21	0.864	0.141	0.071	0.064	0.079	0.093	0.078	0.052	0.062	0.036	0.048												
22	0.794	0.287	0.126	0.082	0.060	0.055	0.048	0.036	0.028	0.023	0.022												
23	0.928	0.163	0.132	0.148	0.164	0.180	0.136	0.104	0.146	0.154	0.147												
24	0.602	0.211	0.095	0.062	0.046	0.047	0.043	0.031	0.022	0.020	0.018												
25	0.679	0.110	0.142	0.143	0.165	0.202	0.231	0.210	0.193	0.194	0.206												
26	0.302	0.080	0.039	0.025	0.022	0.021	0.020	0.023	0.013	0.011	0.010												
27	0.608	0.130	0.083	0.054	0.051	0.038	0.041	0.040	0.079	0.089	0.090												
28	0.417	0.076	0.037	0.026	0.022	0.017	0.014	0.022	0.011	0.011	0.010												
29	0.690	0.225	0.122	0.123	0.161	0.191	0.209	0.205	0.193	0.183	0.171												
30	0.322	0.072	0.037	0.028	0.030	0.022	0.018	0.016	0.013	0.012	0.011												
31	0.383	0.131	0.038	0.083	0.098	0.164	0.227	0.245	0.230	0.226	0.235												

EN 50549-2

Clause	Requirement - Test								Result - Remark			Verdict
32	0.363	0.074	0.035	0.024	0.019	0.018	0.015	0.015	0.016	0.016	0.016	0.013
33	0.413	0.143	0.035	0.030	0.051	0.053	0.067	0.063	0.099	0.105	0.100	
34	0.428	0.070	0.030	0.026	0.019	0.016	0.018	0.013	0.013	0.012	0.010	
35	0.652	0.126	0.067	0.125	0.184	0.224	0.238	0.233	0.257	0.237	0.209	
36	0.278	0.065	0.031	0.025	0.020	0.017	0.014	0.015	0.012	0.011	0.010	
37	0.349	0.157	0.050	0.078	0.090	0.146	0.204	0.231	0.217	0.234	0.232	
38	0.329	0.059	0.029	0.018	0.023	0.017	0.015	0.015	0.014	0.014	0.014	
39	0.418	0.085	0.052	0.033	0.017	0.024	0.039	0.048	0.085	0.091	0.098	
40	0.369	0.061	0.029	0.024	0.022	0.014	0.013	0.014	0.012	0.014	0.017	
41	0.019	0.015	0.023	0.031	0.058	0.092	0.120	0.130	0.173	0.194	0.203	
42	0.006	0.006	0.006	0.006	0.009	0.012	0.013	0.016	0.019	0.020	0.020	
43	0.021	0.023	0.035	0.038	0.056	0.097	0.130	0.151	0.170	0.182	0.199	
44	0.011	0.012	0.010	0.009	0.008	0.009	0.009	0.015	0.012	0.017	0.019	
45	0.021	0.020	0.023	0.025	0.032	0.042	0.048	0.044	0.083	0.083	0.074	
46	0.010	0.008	0.009	0.010	0.013	0.013	0.014	0.015	0.018	0.023	0.023	
47	0.016	0.019	0.020	0.018	0.041	0.061	0.064	0.066	0.107	0.133	0.148	
48	0.005	0.006	0.006	0.007	0.009	0.010	0.011	0.011	0.015	0.018	0.017	
49	0.018	0.039	0.026	0.039	0.065	0.101	0.124	0.123	0.149	0.153	0.161	
50	0.008	0.005	0.005	0.004	0.005	0.006	0.008	0.014	0.011	0.012	0.014	

Interharmonics												
P/P _n [%]	0-5	10	20	30	40	50	60	70	80	90	100	
f [Hz]	I [%]											
75	1.280	0.247	0.227	0.091	0.112	0.095	0.074	0.072	0.072	0.073	0.064	
125	1.343	0.255	0.219	0.091	0.104	0.082	0.067	0.064	0.065	0.065	0.063	
175	1.084	0.237	0.131	0.077	0.120	0.142	0.136	0.113	0.114	0.114	0.102	
225	1.051	0.200	0.104	0.064	0.098	0.115	0.090	0.061	0.080	0.117	0.107	
275	0.959	0.204	0.105	0.070	0.182	0.180	0.159	0.140	0.142	0.136	0.120	
325	1.020	0.191	0.098	0.067	0.135	0.126	0.092	0.067	0.079	0.116	0.103	
375	0.989	0.195	0.102	0.073	0.164	0.150	0.129	0.112	0.112	0.106	0.096	
425	1.085	0.210	0.104	0.077	0.129	0.083	0.061	0.056	0.054	0.047	0.041	
475	1.094	0.201	0.098	0.072	0.065	0.049	0.039	0.038	0.035	0.033	0.030	
525	1.061	0.211	0.104	0.069	0.056	0.043	0.037	0.035	0.031	0.030	0.028	
575	0.995	0.207	0.105	0.063	0.080	0.063	0.054	0.054	0.051	0.047	0.045	
625	0.945	0.211	0.122	0.069	0.073	0.059	0.046	0.041	0.037	0.035	0.032	
675	0.907	0.209	0.124	0.076	0.079	0.065	0.055	0.055	0.048	0.046	0.043	
725	0.975	0.216	0.134	0.077	0.076	0.061	0.046	0.043	0.037	0.034	0.031	

EN 50549-2

Clause	Requirement - Test							Result - Remark			Verdict
775	1.006	0.220	0.130	0.083	0.057	0.048	0.039	0.037	0.031	0.031	0.027
825	1.113	0.242	0.132	0.077	0.061	0.047	0.039	0.037	0.031	0.031	0.026
875	1.143	0.262	0.132	0.077	0.065	0.052	0.042	0.038	0.034	0.030	0.027
925	1.166	0.280	0.142	0.082	0.068	0.058	0.044	0.038	0.034	0.033	0.029
975	1.649	0.333	0.161	0.098	0.083	0.068	0.051	0.044	0.039	0.037	0.033
1025	2.546	0.507	0.235	0.130	0.134	0.115	0.060	0.050	0.053	0.045	0.034
1075	3.028	0.744	0.349	0.209	0.181	0.151	0.103	0.081	0.084	0.072	0.058
1125	3.007	0.791	0.385	0.253	0.196	0.158	0.124	0.103	0.094	0.084	0.071
1175	1.998	0.738	0.356	0.270	0.152	0.110	0.135	0.112	0.088	0.079	0.075
1225	1.338	0.382	0.189	0.160	0.088	0.073	0.079	0.082	0.047	0.047	0.052
1275	1.279	0.314	0.153	0.095	0.077	0.064	0.064	0.053	0.040	0.038	0.035
1325	1.260	0.312	0.154	0.100	0.090	0.067	0.054	0.050	0.041	0.037	0.035
1375	1.199	0.307	0.154	0.104	0.076	0.064	0.062	0.048	0.040	0.038	0.035
1425	1.528	0.503	0.336	0.233	0.175	0.139	0.117	0.101	0.087	0.077	0.071
1475	1.106	0.287	0.137	0.096	0.076	0.063	0.057	0.050	0.044	0.040	0.036
1525	1.359	0.435	0.313	0.216	0.163	0.137	0.119	0.101	0.087	0.077	0.070
1575	1.028	0.261	0.126	0.075	0.070	0.056	0.055	0.051	0.044	0.041	0.037
1625	1.037	0.258	0.123	0.077	0.069	0.056	0.053	0.051	0.046	0.041	0.038
1675	0.936	0.246	0.113	0.082	0.064	0.057	0.050	0.051	0.045	0.043	0.039
1725	0.894	0.248	0.131	0.096	0.068	0.058	0.050	0.054	0.047	0.045	0.041
1775	0.823	0.223	0.102	0.079	0.061	0.055	0.047	0.052	0.049	0.047	0.045
1825	0.759	0.204	0.096	0.071	0.053	0.050	0.046	0.050	0.047	0.046	0.043
1875	0.718	0.192	0.096	0.063	0.056	0.047	0.047	0.051	0.047	0.046	0.044
1925	0.691	0.180	0.089	0.058	0.049	0.045	0.047	0.050	0.046	0.046	0.045
1975	0.683	0.191	0.118	0.094	0.081	0.076	0.075	0.081	0.082	0.086	0.088

Higher Frequencies											
P/P _n [%]	0-5	10	20	30	40	50	60	70	80	90	100
f [kHz]	I [%]										
2.1	1.838	0.391	0.223	0.199	0.222	0.262	0.281	0.280	0.290	0.295	0.407
2.3	1.673	0.408	0.220	0.168	0.136	0.148	0.158	0.162	0.185	0.202	0.283
2.5	1.441	0.313	0.195	0.161	0.184	0.188	0.180	0.160	0.152	0.139	0.187
2.7	3.080	0.328	0.234	0.166	0.196	0.184	0.176	0.175	0.168	0.167	0.232
2.9	1.978	0.323	0.165	0.150	0.183	0.134	0.122	0.130	0.114	0.121	0.166
3.1	1.607	0.352	0.185	0.186	0.167	0.138	0.128	0.119	0.124	0.120	0.157
3.3	2.945	0.512	0.300	0.208	0.165	0.159	0.170	0.205	0.281	0.288	0.371
3.5	1.470	0.258	0.168	0.159	0.144	0.170	0.195	0.229	0.249	0.239	0.302

EN 50549-2

Clause	Requirement - Test								Result - Remark			Verdict
3.7	2.560	0.413	0.102	0.068	0.066	0.075	0.085	0.114	0.166	0.161	0.185	
3.9	2.415	0.353	0.133	0.078	0.070	0.099	0.140	0.176	0.207	0.209	0.257	
4.1	1.738	0.207	0.093	0.065	0.060	0.070	0.098	0.124	0.158	0.167	0.217	
4.3	1.940	0.325	0.095	0.077	0.060	0.044	0.055	0.080	0.098	0.108	0.143	
4.5	2.057	0.314	0.095	0.082	0.059	0.070	0.097	0.118	0.119	0.128	0.172	
4.7	1.180	0.159	0.074	0.061	0.066	0.072	0.087	0.108	0.130	0.131	0.172	
4.9	1.193	0.292	0.120	0.085	0.070	0.074	0.082	0.084	0.071	0.071	0.098	
5.1	1.376	0.205	0.085	0.053	0.056	0.079	0.101	0.130	0.174	0.176	0.222	
5.3	1.262	0.152	0.091	0.061	0.068	0.061	0.064	0.095	0.119	0.144	0.204	
5.5	0.872	0.166	0.101	0.075	0.076	0.079	0.079	0.081	0.100	0.120	0.171	
5.7	1.211	0.187	0.097	0.081	0.066	0.065	0.075	0.099	0.136	0.169	0.263	
5.9	0.839	0.121	0.074	0.048	0.041	0.045	0.065	0.084	0.076	0.087	0.138	
6.1	0.932	0.139	0.053	0.044	0.043	0.038	0.038	0.044	0.065	0.071	0.101	
6.3	0.721	0.142	0.059	0.048	0.039	0.036	0.053	0.066	0.067	0.068	0.094	
6.5	0.436	0.087	0.052	0.043	0.035	0.029	0.045	0.057	0.060	0.058	0.073	
6.7	0.503	0.105	0.043	0.040	0.037	0.024	0.018	0.025	0.031	0.033	0.043	
6.9	0.576	0.112	0.044	0.041	0.035	0.025	0.029	0.038	0.050	0.051	0.065	
7.1	0.335	0.076	0.039	0.031	0.029	0.019	0.019	0.023	0.031	0.035	0.046	
7.3	0.381	0.074	0.038	0.034	0.033	0.029	0.021	0.016	0.026	0.027	0.036	
7.5	0.356	0.073	0.047	0.037	0.035	0.027	0.021	0.017	0.030	0.034	0.048	
7.7	0.257	0.047	0.030	0.023	0.025	0.017	0.011	0.011	0.022	0.026	0.034	
7.9	0.255	0.052	0.037	0.024	0.022	0.024	0.020	0.014	0.018	0.014	0.019	
8.1	0.277	0.048	0.026	0.016	0.020	0.021	0.020	0.016	0.015	0.015	0.022	
8.3	0.170	0.039	0.029	0.015	0.016	0.018	0.016	0.014	0.010	0.012	0.017	
8.5	0.182	0.032	0.037	0.023	0.021	0.021	0.020	0.016	0.014	0.009	0.012	
8.7	0.196	0.035	0.033	0.020	0.020	0.021	0.020	0.019	0.013	0.009	0.013	
8.9	0.197	0.039	0.033	0.016	0.017	0.018	0.019	0.019	0.012	0.007	0.010	

Note(s):

Each phase output current > 75A, it shall be complied with EN 61000-4-7+A1.

The worst case of three phases has been choose.

EN 50549-2

Clause	Requirement - Test	Result - Remark		Verdict		
4.8	TABLE: Power quality - Voltage fluctuations (Kimax)			P		
Power generating unit (individual device) and power generating system which is $I_n > 75A$						
Voltage fluctuations caused by switching operations						
Grid frequency f [Hz]	50					
Grid voltage U_n [V]	400					
Rated current I_n [A]	166					
Remarks:	K_{imax} : is the ratio between the measured I_{max} and the I_{nom} (nominal current) of the device.					
Reactive set-point control, $Q = 0$						
Max. number of switching operations, N_{10}	1					
Max. number of switching operations, N_{120}	12					
Case of switching operation	Cut-in at 10% of rated power					
Grid impedance angle, ψ_k	30°	50°	70°	85°		
Flicker step factor, $k_f(\psi_k)$	0.262	0.250	0.241	0.214		
Voltage change factor, $k_u(\psi_k)$	1.644	1.534	1.130	1.124		
Maximum inrush current factor k_{imax}	0.104					
Reactive set-point control, $Q = 0$						
Max. number of switching operations, N_{10}	1					
Max. number of switching operations, N_{120}	12					
Case of switching operation	Cut-in at 100% of rated power					
Grid impedance angle	30°	50°	70°	85°		
Flicker step factor, $k_f(\psi_k)$	0.357	0.298	0.250	0.212		
Voltage change factor, $k_u(\psi_k)$	1.640	1.624	1.154	1.123		
Maximum inrush current factor k_{imax}	1.016					
Reactive set-point control, $Q = 0$						
Max. number of switching operations, N_{10}	1					
Max. number of switching operations, N_{120}	12					
Case of switching operation	Service disconnection					
Grid impedance angle	30°	50°	70°	85°		
Flicker step factor, $k_f(\psi_k)$	0.833	0.714	0.655	0.617		
Voltage change factor, $k_u(\psi_k)$	1.650	1.644	1.640	1.612		
Maximum inrush current factor k_{imax}	1.016					
Worst case over all switching operations, k_{imax}	1.016					
Note(s):						
Each phase output current $> 75A$, the voltage fluctuations shall be complied with IEC 61400-21-1.						

EN 50549-2

Clause	Requirement - Test	Result - Remark	Verdict
--------	--------------------	-----------------	---------

4.8	Power quality - Voltage fluctuations (Flicker)								P								
Model	SUN2000-100KTL-M2(400Vac)																
Power generating unit (individual device) and power generating system which is $I_n > 75A$																	
Measurements																	
Parameter	P/P _n (%)	P _{st}				C _{ψk}											
		30°	50°	70°	85°	30°	50°	70°	85°								
1	10	0.00077	0.00071	0.00066	0.00064	0.019	0.017	0.016	0.016								
2	20	0.00079	0.00072	0.00066	0.00064	0.019	0.018	0.016	0.016								
3	30	0.00079	0.00072	0.00066	0.00063	0.019	0.018	0.016	0.015								
4	40	0.00077	0.00071	0.00066	0.00064	0.019	0.017	0.016	0.016								
5	50	0.00079	0.00072	0.00066	0.00064	0.019	0.018	0.016	0.016								
6	60	0.00079	0.00072	0.00066	0.00063	0.019	0.018	0.016	0.015								
7	70	0.00077	0.00071	0.00066	0.00064	0.019	0.017	0.016	0.016								
8	80	0.00079	0.00072	0.00066	0.00064	0.019	0.018	0.016	0.016								
9	90	0.00079	0.00072	0.00066	0.00063	0.019	0.018	0.016	0.015								
10	100	0.00077	0.00071	0.00066	0.00064	0.019	0.017	0.016	0.016								
11	100	0.00079	0.00072	0.00066	0.00064	0.019	0.018	0.016	0.016								
12	100	0.00079	0.00072	0.00066	0.00063	0.019	0.018	0.016	0.015								
Network impedance angle	Measurements																
	P _{st}		P _{lt}		C _{ψk}												
30°	0.00079		0.00079		0.019												
50°	0.00072		0.00072		0.0018												
70°	0.00066		0.00066		0.0016												
85°	0.00064		0.00064		0.0016												
Note(s):																	
Each phase output current > 75A, it shall be complied with IEC 61400-21-1.																	
The worst case of three phases has been choose.																	

EN 50549-2																	
Clause	Requirement - Test				Result - Remark		Verdict										
4.8	Power quality - Voltage fluctuations (Flicker)						P										
Model	SUN2000-115KTL-M2 (400Vac)																
Power generating unit (individual device) and power generating system which is $I_n > 75A$																	
Measurements																	
Parameter	P/P _n (%)	P _{st}				C _{ψk}											
		30°	50°	70°	85°	30°	50°	70°	85°								
1	10	0.00058	0.00054	0.00051	0.00050	0.014	0.013	0.012	0.012								
2	20	0.01632	0.01532	0.01448	0.01418	0.398	0.374	0.353	0.346								
3	30	0.00058	0.00055	0.00052	0.00051	0.014	0.013	0.013	0.012								
4	40	0.00058	0.00055	0.00053	0.00052	0.014	0.013	0.013	0.013								
5	50	0.00058	0.00056	0.00054	0.00053	0.014	0.014	0.013	0.013								
6	60	0.00060	0.00057	0.00054	0.00053	0.015	0.014	0.013	0.013								
7	70	0.00059	0.00057	0.00056	0.00055	0.014	0.014	0.014	0.013								
8	80	0.00078	0.00070	0.00061	0.00058	0.019	0.017	0.015	0.014								
9	90	0.00077	0.00070	0.00063	0.00061	0.019	0.017	0.015	0.015								
10	100	0.00077	0.00071	0.00066	0.00064	0.019	0.017	0.016	0.016								
11	100	0.00079	0.00072	0.00066	0.00064	0.019	0.018	0.016	0.016								
12	100	0.00079	0.00072	0.00066	0.00063	0.019	0.018	0.016	0.015								
Network impedance angle	Measurements																
	P _{st}		P _{lt}		C _{ψk}												
30°	0.01632		0.01632		0.398												
50°	0.01532		0.01532		0.374												
70°	0.01448		0.01448		0.353												
85°	0.01418		0.01418		0.346												
Note(s):																	
Each phase output current > 75A, it shall be complied with IEC 61400-21-1.																	
The worst case of three phases has been choose.																	

EN 50549-2																	
Clause	Requirement - Test				Result - Remark		Verdict										
4.8	Power quality - Voltage fluctuations (Flicker)						P										
Model	SUN2000-100KTL-M2 (480Vac)																
Power generating unit (individual device) and power generating system which is $I_n > 75A$																	
Measurements																	
Parameter	P/P _n (%)	P _{st}				C _{ψk}											
		30°	50°	70°	85°	30°	50°	70°	85°								
1	10	0.00081	0.00086	0.00091	0.00093	0.008	0.008	0.009	0.009								
2	20	0.00084	0.00091	0.00099	0.00102	0.008	0.009	0.010	0.010								
3	30	0.00286	0.00244	0.00188	0.00150	0.028	0.024	0.018	0.015								
4	40	0.00091	0.00105	0.00116	0.00120	0.009	0.010	0.011	0.012								
5	50	0.00107	0.00108	0.00110	0.00111	0.010	0.011	0.011	0.011								
6	60	0.00482	0.00390	0.00271	0.00187	0.047	0.038	0.026	0.018								
7	70	0.00520	0.00419	0.00288	0.00198	0.051	0.041	0.028	0.019								
8	80	0.00616	0.00489	0.00324	0.00210	0.060	0.048	0.032	0.020								
9	90	0.00118	0.00115	0.00114	0.00114	0.012	0.011	0.011	0.011								
10	100	0.00092	0.00083	0.00076	0.00075	0.009	0.008	0.007	0.007								
11	100	0.00100	0.00092	0.00087	0.00086	0.010	0.009	0.009	0.008								
12	100	0.00096	0.00088	0.00082	0.00080	0.023	0.021	0.020	0.020								
Network impedance angle	Measurements																
	P _{st}			P _{lt}		C _{ψk}											
30°	0.00616			0.00616		0.060											
50°	0.00489			0.00489		0.048											
70°	0.00324			0.00324		0.032											
85°	0.00210			0.00210		0.020											
Note(s):																	
Each phase output current > 75A, it shall be complied with IEC 61400-21-1.																	
The worst case of three phases has been choose.																	

EN 50549-2																	
Clause	Requirement - Test				Result - Remark		Verdict										
4.8	Power quality - Voltage fluctuations (Flicker)						P										
Model	SUN2000-115KTL-M2(480Vac)																
Power generating unit (individual device) and power generating system which is $I_n > 75A$																	
Measurements																	
Parameter	P/P _n (%)	P _{st}				C _{ψk}											
		30°	50°	70°	85°	30°	50°	70°	85°								
1	10	0.00109	0.00087	0.00064	0.00061	0.011	0.008	0.006	0.006								
2	20	0.00054	0.00053	0.00052	0.00052	0.005	0.005	0.005	0.005								
3	30	0.00054	0.00052	0.00052	0.00052	0.005	0.005	0.005	0.005								
4	40	0.00054	0.00053	0.00053	0.00053	0.005	0.005	0.005	0.005								
5	50	0.00055	0.00054	0.00053	0.00053	0.005	0.005	0.005	0.005								
6	60	0.00057	0.00057	0.00056	0.00056	0.006	0.006	0.005	0.005								
7	70	0.00058	0.00058	0.00058	0.00058	0.006	0.006	0.006	0.006								
8	80	0.00061	0.00061	0.00062	0.00062	0.006	0.006	0.006	0.006								
9	90	0.00067	0.00066	0.00066	0.00066	0.007	0.006	0.006	0.006								
10	100	0.00137	0.00111	0.00084	0.00073	0.013	0.011	0.008	0.007								
11	100	0.00140	0.00115	0.00085	0.00071	0.014	0.011	0.008	0.007								
12	100	0.00134	0.00110	0.00083	0.00071	0.033	0.027	0.020	0.017								
Network impedance angle	Measurements																
	P _{st}			P _{lt}		C _{ψk}											
30°	0.00140			0.00140		0.033											
50°	0.00115			0.00115		0.027											
70°	0.00085			0.00085		0.020											
85°	0.00073			0.00073		0.017											
Note(s):																	
Each phase output current > 75A, it shall be complied with IEC 61400-21-1.																	
The worst case of three phases has been choose.																	